

PANEL 163RP-1		LOCATION ROOM 163		VOLTS 208Y/120V												
FED FROM	CKT #	MOUNTING Recessed		MAIN												
		PHASE 3	WIRE 4	FEEDER	BUS 225											
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RECP RM 165	1	3	0	0	8646	2882	0	0	720	0	0	1	2	RECP RM 162	2
3		3					2882	720	0	720	0	0	1	4	RECP RM 162	4
5		5					0	0	0	540	0	0	1	6	RECP RM 165	6
7	RECP RM 162	7	1	0	0	540	540	0	0	360	0	0	1	8	RECP RM 165	8
9	RECP RM 165	9	1	0	0	360	0	0	0	900	0	0	1	10	RECP RM 161	10
11	RECP RM 163	11	1	0	0	360	0	0	0	360	0	0	1	12	RECP RM 163	12
13	RECP RM 162	13	1	0	0	540	540	0	0	900	0	0	1	14	RECP RM 161	14
15	RECP RM 165	15	1	0	0	540	0	0	0	360	0	0	1	16	RECP RM 163	16
17	CORR 177	17	1	0	0	900	0	0	0	720	0	0	1	18	RECP RM 160	18
19	LTG ROMM 162	19	1	0	0	540	540	0	0	300	0	0	1	20	FACP RM 161	20
21	RECP RM 163	21	1	0	0	360	0	0	0	500	0	0	1	22	EXHAUST RM 137	22
23	PLATF RECEPTACLES	23	1	0	0	720	0	0	0	0	0	0	1	24	Spare	24
25	MICROWAVE RM 145	25	1	0	0	1350	1350	0	0	0	0	0	1	26	Spare	26
27	Spare	27	1	0	0	0	0	0	0	0	0	0	1	28	Spare	28
29	RFAR	29	1	0	0	1920	0	0	0	0	0	0	1	30	Spare	30
31	COOK TOP RM 145	31	3	0	0	7300	2433	0	0	0	0	0	1	32	Spare	32
33		33					2433	0	0	0	0	0	1	34	Spare	34
35		35					0	0	0	0	0	0	1	36	Spare	36
37	Spare	37	1	0	0	0	0	0	0	0	0	0	1	38	Spare	38
39	Spare	39	1	0	0	0	0	0	0	0	0	0	1	40	Spare	40
41	Spare	41	1	0	0	0	0	0	0	0	0	0	1	42	Spare	42
TOTAL							10565	9055	10835							
TOTAL CONNECTED LOAD (VA)							30455									
(AMPS)																

PANEL 163RP-2		LOCATION ROOM 163		VOLTS 208Y/120V												
FED FROM	CKT #	MOUNTING Recessed		MAIN												
		PHASE 3	WIRE 4	FEEDER	BUS 225											
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	4 PLEX RM 162	1	1	12	20	1920	1920	0	0	1920	20	12	1	2	4 PLEX RM 165	2
3	4 PLEX RM 162	3	1	12	20	1920	0	0	0	1920	20	12	1	4	4 PLEX RM 165	4
5	4 PLEX RM 162	5	1	12	20	1920	0	0	0	1920	20	12	1	6	4 PLEX RM 165	6
7	4 PLEX RM 162	7	1	12	20	1920	0	0	0	1920	20	12	1	8	4 PLEX RM 165	8
9	4 PLEX RM 162	9	1	12	20	1920	0	0	0	1920	20	12	1	10	4 PLEX RM 165	10
11	4 PLEX RM 162	11	1	12	20	1920	0	0	0	1920	20	12	1	12	4 PLEX RM 165	12
13	4 PLEX RM 162	13	1	12	20	1920	1920	0	0	1920	20	12	1	14	4 PLEX RM 161	14
15	4 PLEX RM 162	15	1	12	20	1920	0	0	0	1920	20	12	1	16	4 PLEX RM 161	16
17	4 PLEX RM 162	17	1	12	20	1920	0	0	0	1920	20	12	1	18	4 PLEX RM 161	18
19	4 PLEX RM 161	19	1	12	25	2100	2100	0	0	1920	20	12	1	20	4 PLEX RM 161	20
21	4 PLEX RM 161	21	1	12	20	1920	0	0	0	0	0	0	1	22	Spare	22
23	Spare	23	1	0	0	0	0	0	0	0	0	0	1	24	Spare	24
25	Spare	25	1	0	0	0	0	0	0	0	0	0	1	26	Spare	26
27	Spare	27	1	0	0	0	0	0	0	0	0	0	1	28	Spare	28
29	Spare	29	1	0	0	0	0	0	0	0	0	0	1	30	Spare	30
31	Spare	31	1	0	0	0	0	0	0	0	0	0	1	32	Spare	32
33	Spare	33	1	0	0	0	0	0	0	0	0	0	1	34	Spare	34
35	Spare	35	1	0	0	0	0	0	0	0	0	0	1	36	Spare	36
37	Spare	37	1	0	0	0	0	0	0	0	0	0	1	38	Spare	38
39	Spare	39	1	0	0	0	0	0	0	0	0	0	1	40	Spare	40
41	Spare	41	1	0	0	0	0	0	0	0	0	0	1	42	Spare	42
TOTAL							15540	13440	11520							
TOTAL CONNECTED LOAD (VA)							40500									
(AMPS)																

PANEL 172PP-1		LOCATION ROOM 172		VOLTS 480Y/277V												
FED FROM	CKT #	MOUNTING Recessed		MAIN												
		PHASE 3	WIRE 4	FEEDER	BUS 225											
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	J8 RM 167	1	3	4	60	39905	13302	0	0	39905	60	4	3	2	JB ROOM 167	2
3		3					13302	13302	0	0	0	0	0	4		
5		5					0	0	0	0	0	0	0	6		
7	RM 166	7	3	4	60	39905	13302	0	0	831	15	12	3	8	DOOR MOTOR 170	8
9		9					13302	277	0	0	0	0	0	10		
11		11					0	0	0	0	0	0	0	12		
13	DOOR MOTOR 173	13	3	12	15	1496	499	277	0	831	15	12	3	14	DOOR MOTOR 170	14
15		15					499	277	0	0	0	0	0	16		
17		17					0	0	0	0	0	0	0	18		
19	J BOX RM 174	19	3	4	60	39905	13302	0	0	0	0	0	1	20	Spare	20
21		21					13302	0	0	0	0	0	1	22	Spare	22
23		23					0	0	0	0	0	0	1	24	Spare	24
25	J8 RM 167	25	3	4	60	39905	13302	13302	0	39905	60	4	3	26	JB FUME HOOD 169	26
27		27					13302	13302	0	0	0	0	0	28		
29		29					0	0	0	0	0	0	0	30		
31	JB BAKE OVEN 169	31	3	4	60	39905	13302	0	0	0	0	0	1	32	Spare	32
33		33					13302	0	0	0	0	0	1	34	Spare	34
35		35					0	0	0	0	0	0	1	36	Spare	36
37	Spare	37	1	0	0	0	0	0	0	0	0	0	1	38	Spare	38
39	Spare	39	1	0	0	0	0	0	0	0	0	0	1	40	Spare	40
41	Spare	41	1	0	0	0	0	0	0	0	0	0	1	42	Spare	42
TOTAL							94164	94164	94164							
TOTAL CONNECTED LOAD (VA)							282493									
(AMPS)																

PANEL 144RP-1		LOCATION ROOM 144		VOLTS 208Y/120V												
FED FROM	CKT #	MOUNTING Recessed		MAIN												
		PHASE 3	WIRE 4	FEEDER	BUS 225											
CKT	LOAD SERVED	SLOT	POLES	WIRE SIZE	TRIP	VOLT AMPS	PHASE LOAD (VA)			VOLT AMPS	TRIP	WIRE SIZE	POLES	SLOT	LOAD SERVED	CKT
							A	B	C							
1	RECEP XEROX	1	3	0	0	2880	960	1440	0	1440	0	0	1	2	RECEPTACLE	2
3		3					1260	480	0	1260	0	0	1	4	RECEPTACLE	4
5		5					1080	0	0	1080	0	0	1	6	RECEPTACLE	6
7	DISHWASHER	7	1	0	0	1000	1000	0	0	720	0	0	1	8	REFRIGERATOR	8
9	RECEPTACLE	9	1	0	0	360	1260	360	0	1260	0	0	1	10	RECEPTACLE	10
11	RECEPTACLE	11	1	0	0	1260	0	0	0	1000	0	0	1	12	RECEPTACLE	12
13	HEATER RM 139	13	1	0	0	7500	7500	0	0	1380	0	0	1	14	RECEPTACLE	14
15	RECEPTACLE GF1	15	1	0	0	1260	1260	0	0	1000	0	0	1	16	RECEPTACLE	16
17	RECEPTACLE	17	1	0	0	180	0	0	0	1260	0	0	1	18	RECEPTACLE	18
19	RECEPTACLE	19	1	0	0	1260	1260	0	0	1260	0	0	1	20	RECEPTACLE	20
21	RECEPTACLE	21	1	0	0	1260	0	0	0	1080	0	0	1	22	RECEPTACLE	22
23	DISPOSAL	23	1	0	0	1150	0	0	0	4000	0	0	1	24	HEATER RM 141	24
25	RECEPTACLE	25	1	0	0	1080	1080	0	0	7500	0	0	1	26	HEATER STORAGE 144	26
27	HEATER RM 146	27	1	0	0	7500	7500	0	0	4000	0	0	1	28	HEATER RM 142	28
29	RECEPTACLE	29	1	0	0	1080	0	0	0	7500	0	0	1	30	HEATER RM 123	30
31	HEATER RM 143	31	1	0	0	4000	4000	0	0	0	0	0	1	32	Spare	32
33	RECEPTACLE	33	1	0	0	1080	0	0	0	7500	0	0	1	34	HEATER RM 140	34
35	HEATER STORAGE 144	35	1	0	0	4000	0	0	0	1800	0	0	1	36	RECEPTACLE GF1	36
37	PATIO FIXTURE	37	1	0	0	54	54	2310	0	2310	0	0	1	38	ROOM 121 & 122	38
39	EXHAUST MOTOR RM 149	39	1	0	0	1176	0	0	0	900	0	0	1	40	ROOM 122	40
41	Spare	41	1	0	0	0	0	0	0	4000	0	0	1	42	HEATER CORR 146	42
TOTAL							34064	28156	28190							
TOTAL CONNECTED LOAD (VA)							90410									
(AMPS)																

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.