

DUCT SILENCER SCHEDULE

UNIT NO	LOCATION	SERVICE		CFM	DIMENSIONS W X D X L	PD IN. WC	MANUFACTURER/ MODEL NO	REMARKS
		BUILDING	ROOM					
L-CS-107-ST-01	MECH ROOM 107	LVEA	LASER AREA - 1	10,500	48 X 36 X 120	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-02	MECH ROOM 107	LVEA	LASER AREA - 2	15,000	48 X 60 X 120	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-03	MECH ROOM 107	LVEA	LASER AREA - 3	15,000	48 X 60 X 120	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-04	MECH ROOM 107	LVEA	LASER AREA - 4	10,000	48 X 36 X 120	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-05	MECH ROOM 107	LVEA	LASER AREA - 5	10,000	48 X 36 X 120	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-06	MECH ROOM 107	LVEA	MECHANICAL ROOM #107	6,000	48 X 24 X 84	0.07	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-07	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	20,300	60 X 60 X 84	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-08	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	20,300	60 X 60 X 84	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-09	MECH ROOM 107	LVEA	GENERAL RETURN OF LVEA	20,300	60 X 60 X 84	0.10	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-10	MECH ROOM 107	OSB	OSB COLD AIR DECK	24,000	60 X 48 X 84	0.25	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-11	MECH ROOM 107	OSB	OSB WARM AIR DECK	24,000	60 X 48 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-12	MECH ROOM 107	OSB	OSB RETURN AIR	24,000	60 X 60 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-CS-160-ST-13	MECH ROOM 160	OFFICES	SUPPLY AIR	9,700	42 X 18 X 60	0.40	INDUSTRIAL ACOUSTICS CO MS	
L-CS-160-ST-14	MECH ROOM 160	OFFICES	RETURN AIR	9,000	42 X 18 X 60	0.36	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-15	MECH ROOM 107	LVEA	OUTSIDE AIR	2,600	24 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-16	MECH ROOM 107	LVEA	OUTSIDE AIR	2,600	24 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-17	MECH ROOM 107	OSB	OUTSIDE AIR	650	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-18	MECH ROOM 107	OSB	OUTSIDE AIR	650	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-19	ROOM 149	OFFICES	TOILET EXHAUST	950	14" X 36"	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-20	ROOM 149	OFFICES	TOILET EXHAUST	950	14" X 36"	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-21	ROOM 137	OFFICES	TOILET EXHAUST	200	12" X 36"	0.02	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-22	ROOM 137	OFFICES	TOILET EXHAUST	200	12" X 36"	0.02	INDUSTRIAL ACOUSTICS CO MS	
L-CS-107-ST-23	ROOM 169	OSB	EF-04 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO MS	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-CS-107-ST-24	ROOM 169	OSB	EF-04 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO MS	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-CS-107-ST-25	ROOM 168	OSB	EF-03 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO MS	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-CS-107-ST-26	ROOM 168	OSB	EF-03 (FUME HOOD)	800	20 X 20 X 36	0.05	INDUSTRIAL ACOUSTICS CO MS	304 S/S PACKLESS CONSTRUCTION, 12"Ø
L-EA-203-ST-01	MECH ROOM 203	ENDSTATION - A	EXPERIMENT EG.	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-02	MECH ROOM 203	ENDSTATION - A	CLEANING AREA	840	12 X 24 X 84	0.07	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-03	MECH ROOM 203	ENDSTATION - A	VEA	8,400	30 X 30 X 84	0.20	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-04	MECH ROOM 203	ENDSTATION - A	INSPECTION	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-05	MECH ROOM 203	ENDSTATION - A	MECH RM	2,200	18 X 24 X 60	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-06	MECH ROOM 203	ENDSTATION - A	RETURN	8,400	32 X 32 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-07	MECH ROOM 203	ENDSTATION - A	RETURN	4,200	24 X 24 X 84	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-08	MECH ROOM 203	ENDSTATION - A	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-09	MECH ROOM 203	ENDSTATION - A	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EA-203-ST-10	MECH ROOM 203	ENDSTATION - A	VE	1680	12 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-01	MECH ROOM 203	ENDSTATION - B	EXPERIMENT EG.	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-02	MECH ROOM 203	ENDSTATION - B	CLEANING AREA	840	12 X 24 X 84	0.07	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-03	MECH ROOM 203	ENDSTATION - B	VEA	8,400	30 X 30 X 84	0.20	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-04	MECH ROOM 203	ENDSTATION - B	INSPECTION	560	12 X 24 X 84	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-05	MECH ROOM 203	ENDSTATION - B	MECH RM	2,200	18 X 24 X 60	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-06	MECH ROOM 203	ENDSTATION - B	RETURN	8,400	32 X 32 X 84	0.15	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-07	MECH ROOM 203	ENDSTATION - B	RETURN	4,200	24 X 24 X 84	0.12	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-08	MECH ROOM 203	ENDSTATION - B	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-09	MECH ROOM 203	ENDSTATION - B	OUTSIDE AIR	400	18 X 12 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	
L-EB-203-ST-10	MECH ROOM 203	ENDSTATION - B	VE	1680	12 X 24 X 60	0.05	INDUSTRIAL ACOUSTICS CO MS	

AIR INLET & OUTLET SCHEDULE

UNIT NO	DESCRIPTION	FACE SIZE	NECK SIZE IN X IN	CONSTRUCTION	MANUFACTURER/ MODEL NO	REMARKS
HF-1	HEPA FILTER	48 X 24	12" Ø	STEEL	AMERICAN AIR FILTER PHARMA-GEL PGA-B3	5" DEEP FILTER, (1), (2)
HF-2	HEPA FILTER	24 X 24	10" Ø	STEEL	AMERICAN AIR FILTER PHARMA-GEL PGA-B2	5" DEEP FILTER, (1), (2)
CD-1	CEILING DIFFUSER	24 X 24	(3)	ALUMINUM	TITUS TUB-4A	W/OBD
CD-2	CEILING DIFFUSER	N/A	(3)	ALUMINUM	TITUS TUB-4A	W/BUTTERFLY DAMPER
RR-1	RETURN REGISTER	(3)	N/A	ALUMINUM	TITUS 371	W/OBD
RR-2	RETURN REGISTER	(3)	N/A	ALUMINUM	TITUS 371	W/OBD
RG-1	RETURN GRILLE	24 X 24	N/A	ALUMINUM	TITUS 300F	
RG-2	RETURN GRILLE	(3)	(3)	ALUMINUM	TITUS 300F	
SR-1	SUPPLY REGISTER	(3)	(3)	ALUMINUM	TITUS 300F	W/OBD

(1) PROVIDE WITH HANGING TAPS, STAINLESS STEEL TRIM, 1/2" INSULATION WITH ALUMINUM FOIL
 (2) INITIAL PRESSURE DROP = 0.50" WC, REPLACEMENT PRESSURE DROP = 2.0" WC
 (3) SEE PLANS

VIBRATION ISOLATOR SCHEDULE

UNIT NO	NAME	LOCATION	(2) ISOLATOR TYPE	(3) SPRING DEFLECTION (INCH)	(2) FRAME TYPE	(2) SEISMIC RESTRAINT	REMARKS
L-CS-107-SF-01, 02, 03, 04	VANE AXIAL FAN	CORNER STATION	B	1.0	G	SL	(TYP 4) FANS
L-CS-107-SF-05, 06	VANE AXIAL FAN	CORNER STATION	B	1.0	G	SL	(TYP 2) FANS
L-EA-203-SF-01, 02	VANE AXIAL FAN	END STATION-A	B	1.0	G	SL	(TYP 2) FANS
L-EB-203-SF-01, 02	VANE AXIAL FAN	END STATION-B	B	1.0	G	SL	(TYP 2) FANS
L-CS-190-CH-01, 02, 03	AIR-COOLED WATER CHILLER	CORNER STATION	C	1.0	-	(1)	(TYP 3) CHILLERS
L-EA-200-CH-01, 02	AIR-COOLED WATER CHILLER	END STATION-A	C	1.0	-	(1)	(TYP 2) CHILLERS
L-EB-200-CH-01, 02	AIR-COOLED WATER CHILLER	END STATION-B	C	1.0	-	(1)	(TYP 2) CHILLERS
L-CS-190-WP-01, 02, 03	CHILLED WATER PUMP	CORNER STATION	C	1.0	G	SL	(TYP 2) PUMPS
L-EA-200-WP-01, 02	CHILLED WATER PUMP	END STATION-A	C	1.0	G	SL	(TYP 2) PUMPS
L-EB-200-WP-01, 02	CHILLED WATER PUMP	END STATION-B	C	1.0	G	SL	(TYP 2) PUMPS
L-CS-107-AC-01, 02	AIR COMPRESSOR	CORNER STATION	C	1.0	G	SL	(TYP 2) COMPRESSORS
L-EA-203-AC-01, 02	AIR COMPRESSOR	END STATION-A	C	1.0	G	SL	(TYP 2) COMPRESSORS
L-EB-203-AC-01, 02	AIR COMPRESSOR	END STATION-B	C	1.0	G	SL	(TYP 2) COMPRESSORS
L-CS-160-AH-04	PACKAGED AIR HANDLER	CORNER STATION	B	1.0	G	SL	
L-CS-149-EF-01	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-CS-137-EF-02	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-CS-168-EF-03	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-CS-169-EF-04	IN-LINE EXHAUST FAN	CORNER STATION	D	1.0	-	SC	
L-EA-200-EF-01	IN-LINE EXHAUST FAN	END STATION-A	D	1.0	-	SC	
L-EB-200-EF-01	IN-LINE EXHAUST FAN	END STATION-B	D	1.0	-	SC	
L-CS-107-GP-01	GLYCOL FEED PUMP	CORNER STATION	C	1.0	G	SL	
L-EA-203-GP-01	GLYCOL FEED PUMP	END STATION-A	C	1.0	G	SL	
L-EB-203-GP-01	GLYCOL FEED PUMP	END STATION-B	C	1.0	G	SL	
L-CS-195-FP-01	FIRE PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-195-FP-02	FIRE PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-195-JP-03	JOCKY PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-196-DP-04	DOMESTIC WATER PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-196-DP-05	DOMESTIC WATER PUMP	CORNER STATION	C	1.0	G	SL	
L-CS-196-AH-05	PACKAGED AIR HANDLER	CORNER STATION	D	1.0	-	SC	

(1) ISOLATOR HOUSING INCLUDES SEISMIC RESTRAINTS
 (2) SEE SPECIFICATIONS FOR CODE LETTER
 (3) STATIC DEFLECTION 3 HZ

NOTES:
 1. FOR LEGEND, ABBREVIATIONS AND GENERAL NOTES SEE SHEETS LA-H-001 AND LA-H-002.

This document and the design it covers are the property of PARSONS. They are loaned only with the borrower's expressed written agreement that they will not be reproduced, copied, loaned, exhibited, or used in any other way, except by written consent from PARSONS to the borrower.

NO.	DATE	BY	CHKD	ENGR	PROJ	DESCRIPTION
B	7-24-96	CLP				ISSUED FOR BID
A	6-14-96	CLP				FINAL DESIGN REVIEW

PARSONS
 100 WEST WALNUT STREET
 PASADENA, CALIFORNIA

LIGO
 CALIFORNIA INSTITUTE OF TECHNOLOGY
 MASSACHUSETTS INSTITUTE OF TECHNOLOGY

LASER INTERFEROMETER
 GRAVITATIONAL-WAVE OBSERVATORY
 SITE NO. 2 - LIVINGSTON, LOUISIANA

HVAC
 EQUIPMENT SCHEDULES
 SHEET 4

LA-H-006

Mon Jul 22 12:37:19 1996 s3-v18b2 J:\PLOTS\QUEUES\18B2\MU006B.PRF