



D I/O DISTRIBUTION PANEL WIRING

NOTES:

1. ALL WIRING AND EQUIPMENT TO BE PER APPLICABLE CODES, REGULATIONS AND RULES.
2. UNLESS MARKED OTHERWISE, USE #14/1C STRANDED, TYPE THHN/THWN, RATED 90 DEGREES C DRY WIRE.
3. WORK THIS DRAWING WITH DWGS. #ER-250, ER-253, ER-254, ER-255, ER-258, ER-259, ER-261

INDICATES CHANGE FROM PREVIOUS ISSUE

REV'D OXY. MONITOR TERMINATIONS		CORRECTED CARD TERMINAL #'S FOR ALARM & DIALER		ADDED (1) PC PER SKID	
BY	DATE	BY	DATE	BY	DATE
DWC	12 JUL 96	DWC	12 JUL 96	DWC	22 MAY 96
REVISIONS					
REMARKS					
SECTION TEST CONTROL ROOM					
D I/O DISTRIBUTION PANEL WIRING					
LIGO - ER					
CUSTOMER'S NO				CONTRACT NO	
BY DWC CHKD BS DATE 25MAR96				953571	
PSE				DWC ER-256	
ENGINEERING ASSIGNED				SMT	
LIGO-D970044-03-B					