

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA					ENGINEERING CALCULATIONS	NO: V049-1- 160 PAGE 1 OF 22
REV.	DEO #	DATE	BY:	CHECK	TITLE: Washington Site Redesign of Equipment Anchorage for Extended Grout Pads	
0	0556	10/6/97	ROC	<i>[Signature]</i>		
					BY: R. D. Ciatto	DEPT.: 744
<u>PROJECT:</u> LIGO Vacuum Equipment					<u>PROJECT NO:</u> V59049	
<u>PURPOSE:</u> The as-built floor elevations at the corner station and the left end station of the Washington site are more than 1 inch lower than planned. This calculation evaluates the effects of extending the equipment grout pads to accommodate the low floors on the anchorage design.						
<u>METHOD:</u> Hand calculations are performed to determine the maximum anchor bolt tensile and shear forces. These are compared to allowable forces published by Hilti for the HVA concrete anchor system.						
<u>ASSUMPTIONS:</u> See calculation.						
<u>INPUTS:</u> See calculation for unbalanced forces and anchor loads derived in other calculations.						
<u>REFERENCES:</u> 1. Hilti Product Technical Guide, 1995. 2. Amer. Concrete Inst., ACI 318-89, Building Code Rq'mts for Reinforced Concrete. 3. Rogers Surveying, Survey Data for LIGO - Hanford, Job No. 15597, transmitted with TIM 70.						
<u>CALCULATIONS:</u> (SEE ATTACHED)					NOV 14 1997	
<u>CONCLUSIONS:</u> Required modifications to the vacuum equipment concrete anchorage are summarized on sheets 4 and 5 of this calculation.						
<u>NOTES:</u> Modifications resulting from this evaluation are implemented in RFCs V049 - 072 to - 076.						

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 2 of 22
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

TABLE OF CONTENTS

Revision History	3
Required Changes	4
Shear Bars	5
Summary of Results	6
Detailed Calculations	7

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 3 of 22
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

REVISION HISTORY

Rev. 0 Original Issue - Oct. 1997

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 4 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Required Changes

1. All rod length must increase at corner station and end station for the left arm.
2. Shear bars must be added to underside of base plates for WBSC-7 & 8, WB-6,7,2A,2B,3A, & 5A, and WB-9A & 9B.
3. Change anchor rod from HAS standard to HAS super for mode cleaner tubes:


WB-2A
WB-2B
WB-3A
WB-5A

This change is required only at base plates connected to diagonal members.


4. Roughen concrete floor with 1/4 inch indentations.
5. Increase preload torque on super rods to 400 ft-lb and decrease torque on standard rods to 250 ft-lb.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 5 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Shear bars are to be added to WBSC-7 and WBSC-8 on undersides of base plates.



Other base plates listed in item 2 of the previous sheet (plates connected to diagonal members) shall be modified to add shear bars as follows.




Bars must be perpendicular to beam centerline.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 7 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Detailed Calculations

The floor height is 1" +/- lower than the design height. The 3" +/- grout pads will become 4" +/- . Assume that the maximum grout pad height is 4.5". (This upper limit was confirmed by the Rogers survey data, Ref. 3.)




The shear, V , on the attachment will cause excessive bending of bolts. Therefore, the grout must resist the load and transfer force to the scarified floor. In the above sketch, the left anchor has sufficient edge distance to the right to resist V , which is also to the right. The right bolt, however, has low shear capacity for that load since the edge distance to the right is so small.

HAMS

High unbalanced loads exist at HAMS at ends of arms. At the Washington site these are WHAMs 1,6,7, and 12. The unbalanced force is 45.5k. For these components the average shear load is

$$F = 45.5/24 \text{ bolts} = 1.9 \text{ k per bolt}$$

$$V = 1.9 \ll V_{\text{alt}} = 8 \text{ k for Hilti HAS standard rod} \quad \text{ok}$$



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 8 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Cryopumps

The unbalanced force is 27.6 k (Ref. V049-1-083, p. 8). Both the long and short pumps have the same shear force in base plates at the diagonal members. But, the short pump has higher tensile loads since legs are closer together.

Long pumps – force at each bolt

$$T = 5.5 \text{ k and } V = 4.3 \text{ k (Ref. V049-1-083, p. 80)}$$

Shear tension interaction

$$S/T = .70 \text{ for the standard rod.}$$

Short pump – force at each bolt

$$T = 10 \text{ k and } V = 4.3 \text{ k (Ref. V049-1-083, p. 38)}$$

$$S/T = .61 \text{ for super rod.}$$

The anchor embedment for both components is 12 3/8 “. At the base plates connected to the diagonal members, 2 anchors have enough edge distance to resist the force through the grout as discussed on the previous sheet. Then, doubling the shear force gives

$$V = 2 \times 4.3 = 8.6 \text{ k}$$

$$V_{\text{all}} = 16.7 \text{ k for the super bolts} \quad \text{ok}$$

Shear tension interaction is

$$\begin{aligned} S/T &= (T/T_{\text{all}})^{5/3} + (V/V_{\text{all}})^{5/3} = (10/16.5)^{5/3} + (8.6/16.7)^{5/3} \\ &= .43 + .33 = .76 \quad \text{ok} \end{aligned}$$

∴ Cryopumps base plates that are anchored with super Hilti HAS rods using a minimum embedment of 12 3/8 “ are acceptable.


PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 9 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Adapters WB-6 and WB-7

These are similar to the short cryopumps. The unbalanced force is 32.2 k (Ref. V049-1-095, p. 8).

T = 11.6 k per bolt (Ref. V049-1-095, p. 42)
V = 5.1 k per bolt " " "
S/T = .75 for the super rod with an embedment of 12 3/8 "

Double the shear force as was done for the cryopump at the base plate connected to the diagonal member.



$$V = 10.2$$

$$S/T = T/T_{all} + V/V_{all}$$

$$= 11.6/16.5 + 10.2/16.7$$

$$= .70 + .61 = 1.28$$

Using the alternate 5/3 interaction formula

$$S/T = (T/T_{all})^{5/3} + (V/V_{all})^{5/3}$$

$$= .56 + .44 = 1.00 \quad \text{ok}$$

Mode Cleaner Tubes

- WB-2A
- WB-2B
- WB-3A
- WB-5A

The unbalanced force is 32.6 k (Ref. V049-1-087, p. 1)

T = 2.7 at base plate connected to diagonal members
V = 4.9 k
S/T = .89 for standard rod with 8 1/4" embedment (Ref. V049-1-087, p. 46)

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 10 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Double the shear force as was done for the cryopumps and WB-6 and WB-7.

$$V = 9.8 \text{ k}$$

Allowable shear force = 7.7k, ultimate shear capacity = 21.8 k. If the bolts are changed to Super,

gives $V_{all} = 16.7 \text{ k}$
 $V < V_{all}$ ok

∴ Use super rod for the base plates connected to the diagonal members. Check interaction.

$$S/T = (2.7/16.5)^{5/3} + (9.8/16.7)^{5/3} = .05 + .41 = .46 \text{ ok}$$

Beam tube manifold WB-1A and WB-1B

The unbalanced force = 18.6 k (Ref. V049-1-088, p. 8)

$$T = 0 \text{ (Ref. V049-1-088, p. 43)}$$

$$V = 2.7 \text{ k per bolt}$$

$$S/T = .63$$

Again, double the bolt shear at the base plate connected to the diagonal member.

$$V = 5.4 \text{ k} < V_{all} \text{ for HAS standard rod with } 8 \text{ } 1/4'' \text{ embedment} \quad \text{ok}$$

Beam tube manifold WB-9A and WB-9B

The unbalanced force is 38.1 k (Ref. V049-1-089, p. 10)

$$T = 0 \text{ (Ref. V049-1-089, p. 36)}$$

$$V = 5.5 \text{ k at base plate connected to the diagonal member}$$

$$S/T = .98 \text{ for HAS standard rod with } 8 \text{ } 1/4'' \text{ embedment}$$

Double the shear at the base plate connected to the diagonal member.

$$V = 11.0 \text{ k}$$

$$V_{all} = 8 \text{ for standard rod}$$


PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 11 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

But, HAS super rod will be used at the base plate connected to the diagonal member.
 $V_{all} = 16.7 > 11.0 \text{ k}$ ok

Beam Splitters

WBSC1 and WBSC3

The unbalanced force = 16 k (Ref. V049-1-032, p. 5)



$$2T \times 84 = 16 \times 70$$

$$T = 6.67 \text{ k per column}$$

$$T = 6.67/4 = 1.7 \text{ k per anchor}$$


$$V = 16/16 = 1 \text{ k average per bolt}$$

Increase T by 25% for prying
 $T = 1.25 \times 1.7 = 2.1$

See sketch to left and below. Most shear is resisted by 1 bolt because edge distance is small for other 3 anchors.
 \therefore Multiply V by 4
 $V = 4 \text{ k per anchor.}$

$$T/T_{all} + V/V_{all} = 2.1/11 + 4/7.7 = .71 < 1$$

HAS standard rod embeded 8 1/4 " is acceptable.




PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 12 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

WBSC2 – This component has negligible unbalanced load. (Ref. V049-1-032, p. 6) ok

WBSC4 – The unbalanced force for this component is 16 k in 2 directions.
(Ref. V049-1-032, p. 7)

The analysis is similar to that performed for WBSC1 and 3. The tensile force is doubled at one plate.



$$T = 2 \times 2.1 = 4.2 \text{ k per bolt}$$

$$\text{Shear } V = 4 \text{ k (same as WBSC1 \& 3)}$$

$$T/T_{\text{all}} + V/V_{\text{all}} = 4.2/11 + 4/7.7 = .38 + .52 = .90 \quad \text{ok}$$

∴ HAS standard rod with an 8 1/4" embedment is acceptable for BSC4.

WBSC5 & WBSC6 – No unbalanced load. ok
Ref. V049-1-032, p. 12

WBSC9 & WBSC10 – End Station

Unbalanced force = 25.4 k (Ref. V049-1-032, p. 13). From the previous sheet for WBSC1 & 3,

$$T = 2.1 \times 25.4/16 = 3.33\text{k}$$

$$V = 4 \times 25.4/16 = 6.35$$

$$T/T_{\text{all}} + V/V_{\text{all}} = 3.33/11 + 6.35/7.7 = .30 + .82 = 1.12 > 1.0$$

for standard rod with 8 1/4" embedment. For super rod with 12 3/8" embedment that is used at the end of the beam tube arm,

$$T/T_{\text{all}} + V/V_{\text{all}} = 3.33/16.5 + 6.35/16.7 = .20 + .38 = .58 \quad \text{ok}$$

Note: All rods for WBSC9 & 10 are HAS super. Rod for base plates at ends of arms have 12 3/8" embed. Rods for other plates have 8 1/4" embedment.

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 13 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

WBSC7 & WBSC8

Unbalanced forces

$$F_x = 45.5 \text{ k}$$

$$F_z = 29.5 \text{ k}$$

Ref. V049-1-024, p. 5.

Tensile force in column due to F_x

$$2T \times 84 = F_x \times 70 = 45.5 \times 70$$

$$T = 19.0 \text{ k}$$

Tensile force in column due to F_z

$$T = 19.0 \times 29.5 / 45.5 = 12.3 \text{ k}$$

Total column tensile force.

$$T = 19.0 + 12.3 = 31.3 \text{ k}$$

Force per bolt with 25 % prying factor,

$$T = (31.3/4) \times 1.25 = 9.8 \text{ k}$$

Maximum shear applied by F_x

$$V = 45.5/4 = 11.4 \text{ k}$$

Interaction:

$$S/T = (T/T_{all})^{5/3} + (V/V_{all})^{5/3} = (9.8/16.5)^{5/3} + (11.4/16.7)^{5/3}$$

$$= (.59)^{5/3} + (.68)^{5/3} = .95 \quad \text{ok}$$

∴ Use HAS super rod with 12 3/8 embedment.





Plate with max tension



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 14 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Check WBSC7 & WBSC8 using forces computed on p. 28 of V049-1-024.

Node 1 T = 1.1 k per bolt
 V = 18.4 k due to F_x (max value)

$T/T_{all} + V/V_{all} = 1.1/16.5 + 18.4/16.7 = 1.17^*$

This is 10% greater than allowable on shear alone.

Node 4 T = 0
 V = 5.8 due to F_x (max value)
 $V/V_{all} = 5.8/17.7 = .35$ ok

Node 7 T = 0
 V = 15.6
 $V/V_{all} = 15.6/16.7 = .95$ ok

Node 10 T = 8.75
 V = 6.5
 $T/T_{all} + V/V_{all} = 8.75/16.5 + 6.5/16.7 = .53 + .39 = .92$ ok

*See the following sheets. Shear will be resisted by shear bars on the bottom of plates.


Check base plate tear out for WBSC7 & 8 which have maximum shear.

V = 18.4 k

Assume that the minimum distance from the hole to the plate edge is 1.0 in. This is very conservative.

$A_v = 2 \times 1 \times 1 = 2 \text{ in}^2$

$f_v = 18.4/2 = 9.2 \text{ ksi}$ ok



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 15 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Check bolt torque for the slip critical connection. Bolt torque for the major components is

$$T = 375 \text{ ft-lb} = 4.5 \text{ in-k}$$

Get bolt tension, F_t

$$T = .20 D F_t \text{ (Ref. Shigley Eq. 7-16)}$$

$$D = 1 \text{ in}$$

$$F_t = 4.5 / (.20 \times 1) = 22.5 \text{ k}$$

Bolt tensile stress, $A_b = .785 \text{ in}^2$

$$f_t = F_t / A_b = 22.5 / .785 = 28.7 \cong .50 F_u$$

$$f_t \ll .50 F_u \text{ for A193 B7, } F_u = 125 \text{ ksi}$$

Get max slip load, P_s (shear), that can be resisted by a single rod.

$$P_s = mnF_t k_s \text{ (Ref. NF-3000, p. 79, ASME III)}$$

$$m = \text{no. of shear planes} = 2 \text{ (NF 3324.6)}$$

$$n = \text{no. of bolts} = 1$$

$$k_s = \text{slip coefficient (Table NF 3324.6(a))}$$

$$= .45 \text{ for zinc silicate paint.}$$

$$P_s = 2 \times 1 \times 22.5 \times .45 = 20.3 \text{ k}$$

\therefore A maximum shear force of 20.3 k can be resisted before the bolt slips and the gap closes.

The slip resistance is an upper bound since Shigley's equation may account for some thread lubrication. Also, the precise slip coefficient, k_s , is not known but is probably not less than .30. To get a lower bound slip resistance, use .30 for both thread friction and k_s .

$$T = .30 D F_t$$

$$F_t = 4.5 / (.30 \times 1) = 15 \text{ k}$$

$$f_t = F_t / A_b = 15 / .785 = 19.1 \text{ ksi}$$

$$P_s = 2 \times 1 \times 15 \times .30 = 9 \text{ k}$$

For HAS super rods increase torque to 400 ft-lb.

$$P_s = 9 \times 400 / 375 = 9.6 \text{ k min value}$$

PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 16 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Hence, shear add bars to base plates connected to diagonal members at:

WBSC7 & 8

WB-6 & 7,

mode cleaner tubes WB-2A, 2B, 3 A & 5A

WB-9A & 9B


Also, chip concrete to expose aggregate at these plates.

Since 400 ft-lb may be too high a torque for HAS standard rods, use 250 ft-lb for these anchors.

$$P_s = 9 \times (250/375) = 6 \text{ k min value} > 5.4 \text{ at WB-1A \& 1B.} \quad \text{ok}$$

The shear force for WBSC7 & 8 is only slightly lower than P_s ; therefore it is necessary to ^{A-D} shear bars to the bottom of the base plates of these units to transfer the shear force to the scarified floor.

Try adding 8"x1" bars to the bottom of each base plate.



PROCESS SYSTEMS INTERNATIONAL, INC. WESTBOROUGH, MA	ENGINEERING CALCULATIONS	NO: V049-1-160
		Rev. No. 0
		Page 17 of 17
PROJECT: LIGO VACUUM EQUIPMENT	PROJECT NO:	V59049
CALCULATION TITLE: Redesign of Equipment Anchorage for Extended Grout Pads		

Bearing stress on grout

$$f = F_x / (8 \times 1) = 18.4 / 8 = 2.3 \text{ ksi} \ll 7 \text{ ksi} \quad \text{ok}$$

Try 1/4" fillet weld

$$f_v = 18.4 / (2 \times 8 \times .707 \times (1/4)) = 6.5 \text{ ksi} < 21 \text{ ksi} \quad \text{ok}$$

Check maximum shear friction between grout and concrete floor

Base plate area $A = 14 \times 14 = 196 \text{ in}^2$ (min – doesn't account for beveled edge of grout pad)

$$V_{\max} = 24 \text{ k (Ref. V049-1-024, p. 38)}$$

$$f_v = 24 / 196 = .122 \text{ ksi} = 122 \text{ psi}$$

Check allowable shear friction from the ACI code.

$$V_n = A_{vf} \times f_y \times \mu \quad \text{(Ref. ACI 11.7.4)}$$

$$A_{vf} = \text{area of Hilti's} = 4 \times .785 = 3.14 \text{ in}^2$$

$$f_y = 60 \text{ ksi max} < F_y \text{ for A193 B7 (Super rods)}$$

$$\mu = 1.0 \lambda$$

$$\lambda = 1.0$$

$$V_n = 3.14 \times 60 \times 1 = 188 \text{ k} \gg 24 \text{ k}$$

But the concrete must be roughened per ACI 11.7.9 to amplitude of 1/4 in.

The maximum shear friction resistance is

$$V_{n \max} = .2 f'_c A_c < 800 A_c \text{ lb (Ref. ACI 11.7.5)}$$

$$f'_c = 4000 \text{ psi for floor}$$

$$A_c = 12 \times 12 = 144 \text{ for small base plate}$$

$$V_{n \max} = .2 \times 4000 \times 144 = 800 \times 144 = 115200 \text{ lb} = 115 \text{ k} \gg 24 \text{ k}$$

ok