High Power Test Facility - a joint ACIGA/LSC Project?

'Initial' Report

David McClelland, David Blair ACIGA

LIGO-G010156-00-Z

LSC Meeting, March 2001.

Purpose: Preliminary list

- Diagnose cavity operation, stability and dynamics at LIGO II circulating power (~ 1MW)
- Investigate thermal deformation and control in high power cavities
- Investigate 'cold' lock up to full operating power, including changes to control and alignment signals

Purpose (ctd)

- field test a high power (>100 W) laser.
- field test high power conditioned input optics
- validate optical cavity modelling codes
- integrate a high power laser system with a high power handling input optics system, a core optics system and a high power photo detection system.

Status

- ARC funding commenced January 2001
- LIGO commitment: core (2) and PR & MC optics
- Completed
 - Central laboratory end stations at 80m
 - 5 vacuum chambers, 160m vacuum pipe

Current


- Outfitting optics laboratory
- Installing vacuum envelope (to LII level)
- Building isolation stacks

Optical Design

Rationale

- Should be as LIGOII like as possible
- Input power, circulating power, spot sizes, cavity stability (g factors), cavity lengths
- Allow results to apply to LIGOII
 - Directly
 - Simple scaling
 - Model validation

?Steps 1: Power Recycling Cavity



Sapphire optics, rear coated, r ~ 0.9975, thermal correction Fused silica optics, PRM thermal correction?


Modecleaner length: 12-18 m

PRC: length ~ 12 -15 m, near unstable, spot size ~ LII, PRF ~ 17.

Main problems


- PRC near unstable for both carrier and sidebands
 - 'worst case scenario'?

Step 2: Output modecleaner?



Steps 3: PR arm cavity


primary outcome for LII?




Staged:

- 80 m stable cavity (g1 g2 \sim 0.3?)
- add PR
- BS may be used as 'pick off' monitor

Option: PR Arm cavity Michelson




Option: dual recycling?



Sapphire optics, rear coated, r ~ 0.9975, thermal correction Fused silica optics, PRM thermal correction?

PRC: length ~ 12 -15 m, near unstable, spot size \sim LII, PRF ~ 17 . SRC, factor variable?

Option: dual recycling with OMC?



Proposal:

- Establish the Gingin high power interferometer test facility (HPITFC) as an LSC Facility
- Advisory board:

- Reitze, U. Florida

- Zucker, MIT

Camp, Caltech (chair)

Willke, GEO

- Sanders, Caltech

• Chair?

Insert in LIGOII planning process

Blair, UWA

Munch, AU

McClelland, ANU

Action:

- Advisory group to meet at Amaldi
- Brainstorm on:
 - short Michelson ?
 - PR Cavity but with what parameters?
 - PR arm cavity?
 - Scheduling & Milestones?